

ADDENDUM 001
REQUEST FOR QUOTE
Remove and Install Garage Door
RFQ NUMBER: D1-07-173

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original quote. Accordingly, the change is believed to be of general interest to all potential bidders. The original solicitation is hereby changed to make revision throughout the document. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Brenda Christie Procurement Agent
Contractor/Offeror Signature	Department of Transportation <i>Brenda Christie</i>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: <i>May 14, 2007</i>

Questions and Answers

1. Do you want a new motor installed and complete reversing edge?

Answer: Yes, this is for safety reasons.

2. What is the existing height?

Answer: 11'

3. Is this model number a prefinish door?

Answer: Yes

4. Do you want the bottom of the lintel painted?

Answer: Yes with brown enamel paint.

5. Do you want the controls replaced also?

Answer: Yes, replaced with new motor and new controls.

6. Will the rafters have to be cut in order to make room for the tracking?

Answer: Yes, will need to notch out some of the rafters to make it fit.